


Chaska Fire Department Policy Requirement for Fire Lane Safety



(Not to scale)

1. Safety signs to be a minimum of 12" x 18".
2. Red on white is preferred.
3. 3M or equal engineer's grade reflective sheeting on aluminum is preferred.
4. Wording shall be: **NO PARKING
FIRE LANE**
5. Signs shall be posted at each end of the fire lane and at least at 75 foot intervals along the fire lane.
6. All signs shall be double sided facing the direction of travel.
7. Post shall be set back a minimum of 12" but not more than 36" from the curb.
8. A fire lane shall be required in front of Fire Department connections extending 5 feet on each side and along all areas designated by the Fire Chief.

ANY DEVIATION FROM THE ABOVE PROCEDURES SHALL BE SUBMITTED IN WRITING, WITH A SITE PLAN, FOR APPROVAL BY THE FIRE CHIEF. IT IS THE INTENTION OF THE FIRE DEPARTMENT TO ENSURE CONTINUITY THROUGHOUT THE CITY BY PROVIDING THESE PROCEDURES FOR MARKING OF FIRE LANES.

Approved by Building Official, City of Chaska

Approved by Fire Marshal, City of Chaska